

Certificate of Compliance

Awarded to:

Lubrizol LifeSciences



TSS certifies that:

Cleanroom, located at Lubrizol LifeSciences 547 TRM Circle, , meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-8) for particles $\geq 0.5 \mu\text{m}$ and $\geq 5.0 \mu\text{m}$ under Operational/Dynamic conditions.

Refer to TSS Project Report LA-VST22505G-1 for supporting data.

Presented by:



620 Hearst Avenue, Berkeley, CA 94710
(800) 877-7742 - www.techsafety.com

Effective Date: 12/13/2022

Expiration Date: 12/13/2023

Approved By: Audrey Barnett
Technical Writer
Technical Safety Services (TSS)

Certificate of Compliance

Awarded to:

Lubrizol LifeSciences



TSS certifies that:

Gown, located at Lubrizol LifeSciences 547 TRM Circle, , meets the acceptance criteria of ISO 14644-1:2015(Class: ISO-8) for particles $\geq 0.5 \mu\text{m}$ and $\geq 5.0 \mu\text{m}$ under Operational/Dynamic conditions.

Refer to TSS Project Report LA-VST22505G-1 for supporting data.

Presented by:



620 Hearst Avenue, Berkeley, CA 94710
(800) 877-7742 - www.techsafety.com

Effective Date: 12/13/2022

Expiration Date: 12/13/2023

Approved By: Audrey Barnett
Technical Writer
Technical Safety Services (TSS)